

14515 Pioneer Way E  
Puyallup WA 98372  
(253)841-9698  
www.valleywaterdistrict.com  
Email: [service@valleywaterdistrict.com](mailto:service@valleywaterdistrict.com)  
Sean Vance, District Manager  
Brian Thompson, Field Supervisor

## Drinking Water Quality Report for

### Puyallup Highlands

Puyallup (located in the Valley System)

Water System ID #01250(Valley)

# 2020

In this report, you will find information about:

#### **YOUR WATER**

Your Water System

Arsenic Information

Source Water Protection

Cross-Connection Control

#### **TEST RESULTS**

Possible Contaminants

Key Table Definitions

Lead Information

City of Puyallup Water Quality Table

#### **WHERE DOES MY WATER COME FROM?**

The water source for the Puyallup Highlands is fed through an intertie with the City of Puyallup. Valley Water District owns and operates the water distribution system infrastructure within the Puyallup Highlands subdivision and purchases water from the City of Puyallup. The last page of this report contains the water quality monitoring information provided by the City of Puyallup.

#### **HOW IS MY WATER TREATED?**

Your water is treated by filtration and disinfection. Filtration removes particles suspended in the source water. Particles typically include clays and silts, natural organic matter, iron and manganese, and microorganisms. Disinfection involves the addition of chlorine or other disinfectants to kill dangerous bacteria and microorganisms (viruses, cysts, etc.) that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

#### **INFORMATION ABOUT ARSENIC:**

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

*We are proud to report that this system meets all state and federal guidelines for regulated contaminants, and is significantly below the EPA's required safety levels.*

# Water Quality Report Information



**Valley Water District** is pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

**Valley Water District** vigilantly safeguards and routinely monitors your drinking water. We are providing this report as a snapshot of water quality monitoring for the calendar year of the report (unless otherwise noted). The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old.

## How Can I Get Involved?


We want our valued customers to be informed about their water utility. If you would like to learn more, please attend any regularly scheduled Board Meeting held at the District Office on the first and third Tuesday of each month, at 7:00pm.

## Questions?

If you have any questions about the information in this report, or any concern regarding water quality and the services we deliver every day, please contact the District office at 253-841-9698.

Sean Vance, District Manager ~ Brian Thompson, Field Supervisor ~ Email: [service@valleywaterdistrict.com](mailto:service@valleywaterdistrict.com)

**Visit [www.wateruseitwisely.com](http://www.wateruseitwisely.com) for great water saving tips!**



## Possible Contaminants

Common sources of drinking water—both tap and bottled water—include rivers, lakes, streams, ponds, and reservoirs (surface water), and wells and springs (groundwater).

As water travels over the surface of the land or through the ground, naturally occurring minerals and, in some cases, radioactive materials dissolve in the water.

Water can also pick up substances resulting from the presence of animals or human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk.

More information about contaminants and potential health effects can be obtained by calling EPA's Safe Drinking Water Hotline (1-800-426-4791).

Contaminants that may be present in source water include:

**Microbial contaminants**, such as viruses, parasites, and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife.

**Inorganic contaminants**, such as salts and metals, which can occur naturally or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, and farming.

**Pesticides and herbicides**, which may come from various sources such as agriculture, urban stormwater runoff, and residential uses.

**Organic Chemical Contaminants**, including synthetic and volatile organic chemicals which are by-products of industrial processes and petroleum production. They can also come from gas stations, urban stormwater runoff, and septic systems.

**Radioactive Contaminants**, which can occur naturally or result from oil and gas production and mining activities.

*In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.*

## VULNERABLE POPULATIONS

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

## WHAT YOU CAN DO TO PROTECT SOURCE WATER:

- Ensure that your septic system is properly maintained.
- Use chemical fertilizers and pesticides sparingly, if at all.
- Don't dump any hazardous waste on the ground or down the drain. This includes motor oil, pesticides, paint, household cleaners, medicines, etc.

## Check the SWAP information for your water system:

The WA State Department of Health Office of Drinking Water has compiled Source Water Assessment Program (SWAP) data for all community water systems. An interactive map with data for your water system is available at: <https://fortress.wa.gov/doh/swap/index.html>

## Cross-Connection Control Survey

The purpose of this survey is to determine whether a cross-connection may exist at your home or business.

A cross connection is an unprotected or improper connection to a public water distribution system that may cause contamination or pollution to enter the system.

Valley Water District is responsible for enforcing cross-connection control regulations and insuring that no contaminants can, under any flow conditions, enter the distribution system.

If you have any of the devices listed below, please contact us so that we can discuss the issue, and if needed, survey your connection and assist you in isolating it if that is necessary.

Do you have one of these at your home or business?

- Lawn irrigation system
- Pool or hot tub
- Decorative pond or fountain
- Watering trough
- Fire sprinkler system
- Additional source(s) of water on the property



If you do, Washington State law may require that you have a “Backflow Prevention Assembly”. The purpose of this device is to provide “cross connection control” - preventing contaminated water from flowing back into your drinking water - a serious health hazard.

However, even the best Backflow Prevention Assembly can fail because of freezing, debris, improper installation and unapproved plumbing connections. For this reason, the state’s Department of Health requires these devices to be tested annually by a certified backflow assembly tester, with a copy of the test record sent to Valley Water District.

### Customers with a BACKFLOW ASSEMBLY:

### Consider “Opting In” to our TESTING PROGRAM!

In 2018, the District created a program that allows customers with backflow devices that are required to have annual testing done to “OPT IN” and have the District coordinate with a contractor to perform the test at a significantly reduced rate of \$26.00 per device (most testers charge \$40-\$90 per device). It’s not too late to opt in if you haven’t yet, you can find the Backflow Testing Agreement on the District website at [www.valleywaterdistrict.com](http://www.valleywaterdistrict.com) under FORMS.



If you are already opted in...no need to worry about future testing. Every year between May and September, the District will automatically have the contractor, Randy Horne with Aqua Backflow Testing, perform the testing for each property that has opted in.

## KEY TABLE DEFINITIONS

**Action Level (AL):** The concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to MCLGs as feasible using the best available technology.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Minimum Reporting Level (MRL):** Also known as the Method Reporting Limit: The smallest amount of a substance that can be reliably quantitated in sample.

**NA:** Not Applicable

**Nephelometric Turbidity Unit (NTU):** a standard to measure water clarity.

**Not Detected (ND):** This compound was analyzed and not detected at a level greater than or equal to the State Detection Reporting Level.

**PPB =** Parts per billion

**PPM =** Parts per million

**µmhos/cm =** The basic unit of measurement of conductivity.

**mg/L =** milligrams per liter

**Secondary Maximum Contaminant Level (SMCL):** These standards are developed as guidelines to protect the aesthetic qualities of drinking water and are not health based.

**State Detection Reporting Limit (SDRL):** The minimum reportable detection of an analyte as established by DOH.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

**Variations and Exemptions:** State or EPA permission not to meet an MCL, an action level, or a treatment technique under certain conditions.

### Information About Lead...

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Valley Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.

If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline 1-800-426-4791 or online at <http://www.epa.gov/safewater/lead>.

## 2020 Water Quality Table provided by City of Puyallup

WATER QUALITY TABLE						
Substance	MCL {MRDL}	MCLG {MDRLG}	Highest Level Detected	Range Low - High	Violation	# of Sites
Arsenic (ppb)	10	0	7	ND-7	N	1
Chlorine (ppm)	4	4	1.3	0.2-1.3	N	1
HAA5 (ug/L) (stage 2)	60	N/A	1.1	ND-1.10	N	1
HAA5 (ug/L) (stage 2)*	60	N/A	10.26	8.29-10.26	N	1
Nitrate (ppm)	10	10	2.94	<2-2.94	N	1
TTHMs (ppb)	80	N/A	4.57	3.17-4.57	N	1
TTHMs (ppb)*	80	N/A	36.04	13.06-36.04	N	1
Copper (ppm)	AL 1.3 mg/L	1.3 mg/L	0.0978	Above AL 0/35	N	1
Lead (ppb)	AL 0.015 mg/L	0.015 mg/L	90th% <10 ppb	Above AL 0/35	N	1
Chloride (ppm)	SMCL 250	N/A	17	2.0-17.0	N	1
Iron (ppm)	SMCL 300	N/A	<0.1	<0.1	N	1
Manganese (ppb)	SMCL 50	N/A	80	ND-80	N	1
Sulfate (ppm)	SMCL 250	N/A	8	ND-8	N	1
Bromodichloro-Methane (ppb**)			1.39	1.04-1.39	N	1
Chlorodibromo-Methane (ppb**)			1.7	ND-1.7	N	1
Chloroform (ppb)			1.91	0.77-1.91	N	1
Chloroform (ppb)*			32.44	10.88-32.44	N	1
Sodium (ppm)			28	6.0-28.0	N	1
Barium	2 ppm	2 ppm	<0.01 ppm	<0.01 ppm	N	1
Chromium	100 ppb	100 ppb	< 7 ppb	< 7 ppb	N	1
Nickel	100 ppb	100 ppb	< 5 ppb	< 5 ppb	N	1
<b>HHAs &amp; TTHMs</b>		<b>System Average</b>	<b>Highest Site</b>	<b>Range all Sites</b>		
LRAAs Puyallup	TTHMs	0.00376	0.00457	0.00317-0.00457		1
Localational running annual average	HAAs	0.000275	0.0011	ND-0.0011		1
LRAAs Tacoma	TTHMs	0.022955	0.03604	0.01306-0.03604		1
Localational running annual average	HAAs	0.0091225	0.01026	0.00829-0.01026		1
* City of Tacoma intertie						
** TTHMs detected are covered in the DBP number						
Hardness						
Salmon Springs						77
Maplewood Springs						101